

November 28, 2017

Anna Willis  
Cook County School District 104  
6021 S 74th Ave  
Summit, IL 60501  
TEL: (708) 728-3113  
FAX:



**RE:** Drinking Water Testing - Walsh

**WorkOrder:** 17111269

Dear Anna Willis:

TEKLAB, INC received 24 samples on 11/20/2017 9:20:00 AM for the analysis presented in the following report.

Samples are analyzed on an as received basis unless otherwise requested and documented. The sample results contained in this report relate only to the requested analytes of interest as directed on the chain of custody. NELAP accredited fields of testing are indicated by the letters NELAP under the Certification column. Unless otherwise documented within this report, Teklab Inc. analyzes samples utilizing the most current methods in compliance with 40CFR. All tests are performed in the Collinsville, IL laboratory unless otherwise noted in the Case Narrative.

All quality control criteria applicable to the test methods employed for this project have been satisfactorily met and are in accordance with NELAP except where noted. The following report shall not be reproduced, except in full, without the written approval of Teklab, Inc.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,



Elizabeth A. Hurley  
Project Manager  
(618)344-1004 ex 33  
[ehurley@teklabinc.com](mailto:ehurley@teklabinc.com)



## Report Contents

<http://www.teklabinc.com/>

---

**Client:** Cook County School District 104

**Work Order:** 17111269

**Client Project:** Drinking Water Testing - Walsh

**Report Date:** 28-Nov-17

---

**This reporting package includes the following:**

Cover Letter	1
Report Contents	2
Definitions	3
Case Narrative	4
Accreditations	5
Laboratory Results	6
Receiving Check List	30
Chain of Custody	Appended

**Client:** Cook County School District 104

**Work Order:** 17111269

**Client Project:** Drinking Water Testing - Walsh

**Report Date:** 28-Nov-17

### Abbr Definition

- CCV Continuing calibration verification is a check of a standard to determine the state of calibration of an instrument between recalibration.
- DF Dilution factor is the dilution performed during analysis only and does not take into account any dilutions made during sample preparation. The reported result is final and includes all dilutions factors.
- DNI Did not ignite
- DUP Laboratory duplicate is an aliquot of a sample taken from the same container under laboratory conditions for independent processing and analysis independently of the original aliquot.
- ICV Initial calibration verification is a check of a standard to determine the state of calibration of an instrument before sample analysis is initiated.
- IDPH IL Dept. of Public Health
- LCS Laboratory control sample, spiked with verified known amounts of analytes, is analyzed exactly like a sample to establish intra-laboratory or analyst specific precision and bias or to assess the performance of all or a portion of the measurement system. The acceptable recovery range is in the QC Package (provided upon request).
- LCSD Laboratory control sample duplicate is a replicate laboratory control sample that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).
- MBLK Method blank is a sample of a matrix similar to the batch of associated sample (when available) that is free from the analytes of interest and is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedures, and in which no target analytes or interferences should present at concentrations that impact the analytical results for sample analyses.
- MDL Method detection limit means the minimum concentration of a substance that can be measured and reported with 99% confidence that the analyte concentration is greater than zero.
- MS Matrix spike is an aliquot of matrix fortified (spiked) with known quantities of specific analytes that is subjected to the entire analytical procedures in order to determine the effect of the matrix on an approved test method's recovery system. The acceptable recovery range is listed in the QC Package (provided upon request).
- MSD Matrix spike duplicate means a replicate matrix spike that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).
- MW Molecular weight
- ND Not Detected at the Reporting Limit
- NELAP NELAP Accredited
- PQL Practical quantitation limit means the lowest level that can be reliably achieved within specified limits of precision and accuracy during routine laboratory operation conditions. The acceptable recovery range is listed in the QC Package (provided upon request).
- RL The reporting limit the lowest level that the data is displayed in the final report. The reporting limit may vary according to customer request or sample dilution. The reporting limit may not be less than the MDL.
- RPD Relative percent difference is a calculated difference between two recoveries (ie. MS/MSD). The acceptable recovery limit is listed in the QC Package (provided upon request).
- SPK The spike is a known mass of target analyte added to a blank sample or sub-sample; used to determine recovery deficiency or for other quality control purposes.
- Surr Surrogates are compounds which are similar to the analytes of interest in chemical composition and behavior in the analytical process, but which are not normally found in environmental samples.
- TIC Tentatively identified compound: Analytes tentatively identified in the sample by using a library search. Only results not in the calibration standard will be reported as tentatively identified compounds. Results for tentatively identified compounds that are not present in the calibration standard, but are assigned a specific chemical name based upon the library search, are calculated using total peak areas from reconstructed ion chromatograms and a response factor of one. The nearest Internal Standard is used for the calculation. The results of any TICs must be considered estimated, and are flagged with a "T". If the estimated result is above the calibration range it is flagged "ET"
- TNTC Too numerous to count ( > 200 CFU )

### Qualifiers

- |  |  |
|--|--|
| # - Unknown hydrocarbon                                      | B - Analyte detected in associated Method Blank        |
| E - Value above quantitation range                           | H - Holding times exceeded                             |
| I - Associated internal standard was outside method criteria | M - Manual Integration used to determine area response |
| ND - Not Detected at the Reporting Limit                     | R - RPD outside accepted recovery limits               |
| S - Spike Recovery outside recovery limits                   | T - TIC(Tentatively identified compound)               |
| X - Value exceeds Maximum Contaminant Level                  |  |

**Client:** Cook County School District 104

**Work Order:** 17111269

**Client Project:** Drinking Water Testing - Walsh

**Report Date:** 28-Nov-17

**Cooler Receipt Temp:** NA °C

All samples were collected in 250mL containers.

Date & Time of Last Use: 11/17/17 8:00pm.

### Locations

#### Collinsville

**Address** 5445 Horseshoe Lake Road  
Collinsville, IL 62234-7425

**Phone** (618) 344-1004

**Fax** (618) 344-1005

**Email** jhriley@teklabinc.com

#### Collinsville Air

**Address** 5445 Horseshoe Lake Road  
Collinsville, IL 62234-7425

**Phone** (618) 344-1004

**Fax** (618) 344-1005

**Email** EHurley@teklabinc.com

#### Springfield

**Address** 3920 Pintail Dr  
Springfield, IL 62711-9415

**Phone** (217) 698-1004

**Fax** (217) 698-1005

**Email** KKlostermann@teklabinc.com

#### Chicago

**Address** 1319 Butterfield Rd.  
Downers Grove, IL 60515

**Phone** (630) 324-6855

**Fax**

**Email** arenner@teklabinc.com

#### Kansas City

**Address** 8421 Nieman Road  
Lenexa, KS 66214

**Phone** (913) 541-1998

**Fax** (913) 541-1998

**Email** jhriley@teklabinc.com



## Accreditations

<http://www.teklabinc.com/>

**Client:** Cook County School District 104

**Work Order:** 17111269

**Client Project:** Drinking Water Testing - Walsh

**Report Date:** 28-Nov-17

State	Dept	Cert #	NELAP	Exp Date	Lab
Illinois	IEPA	100226	NELAP	1/31/2018	Collinsville
Kansas	KDHE	E-10374	NELAP	4/30/2018	Collinsville
Louisiana	LDEQ	166493	NELAP	6/30/2018	Collinsville
Louisiana	LDEQ	166578	NELAP	6/30/2018	Collinsville
Texas	TCEQ	T104704515-12-1	NELAP	7/31/2018	Collinsville
Arkansas	ADEQ	88-0966		3/14/2018	Collinsville
Illinois	IDPH	17584		5/31/2019	Collinsville
Indiana	ISDH	C-IL-06		1/31/2018	Collinsville
Kentucky	KDEP	98006		12/31/2017	Collinsville
Kentucky	UST	0073		1/31/2018	Collinsville
Louisiana	LDPH	LA170027		12/31/2017	Collinsville
Missouri	MDNR	930		1/31/2018	Collinsville
Missouri	MDNR	00930		5/31/2017	Collinsville
Oklahoma	ODEQ	9978		8/31/2018	Collinsville
Tennessee	TDEC	04905		1/31/2018	Collinsville



# Laboratory Results

<http://www.teklabinc.com/>

**Client:** Cook County School District 104  
**Client Project:** Drinking Water Testing - Walsh  
**Lab ID:** 17111269-001  
**Matrix:** DRINKING WATER

**Work Order:** 17111269  
**Report Date:** 28-Nov-17  
**Client Sample ID:** A. WF / 204  
**Collection Date:** 11/18/2017 8:17

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	11/28/2017 11:02	136585



# Laboratory Results

<http://www.teklabinc.com/>

**Client:** Cook County School District 104  
**Client Project:** Drinking Water Testing - Walsh  
**Lab ID:** 17111269-002  
**Matrix:** DRINKING WATER

**Work Order:** 17111269  
**Report Date:** 28-Nov-17  
**Client Sample ID:** B. WF / 204  
**Collection Date:** 11/18/2017 8:18

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	11/28/2017 11:08	136585



# Laboratory Results

<http://www.teklabinc.com/>

**Client:** Cook County School District 104  
**Client Project:** Drinking Water Testing - Walsh  
**Lab ID:** 17111269-003  
**Matrix:** DRINKING WATER

**Work Order:** 17111269  
**Report Date:** 28-Nov-17  
**Client Sample ID:** A. WF 4th Grade BR.  
**Collection Date:** 11/18/2017 8:28

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	11/28/2017 11:13	136585





## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Cook County School District 104

**Work Order:** 17111269

**Client Project:** Drinking Water Testing - Walsh

**Report Date:** 28-Nov-17

**Lab ID:** 17111269-004

**Client Sample ID:** B. WF 4th Grade BR.

**Matrix:** DRINKING WATER

**Collection Date:** 11/18/2017 8:29

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	11/28/2017 11:19	136585



# Laboratory Results

<http://www.teklabinc.com/>

**Client:** Cook County School District 104  
**Client Project:** Drinking Water Testing - Walsh  
**Lab ID:** 17111269-005  
**Matrix:** DRINKING WATER

**Work Order:** 17111269  
**Report Date:** 28-Nov-17  
**Client Sample ID:** A. Sink Confren. Rm  
**Collection Date:** 11/18/2017 8:06

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	11/28/2017 12:14	136585



# Laboratory Results

<http://www.teklabinc.com/>

**Client:** Cook County School District 104  
**Client Project:** Drinking Water Testing - Walsh  
**Lab ID:** 17111269-006  
**Matrix:** DRINKING WATER

**Work Order:** 17111269  
**Report Date:** 28-Nov-17  
**Client Sample ID:** B. Sink Confren. Rm  
**Collection Date:** 11/18/2017 8:07

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	11/28/2017 11:24	136585



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Cook County School District 104

**Work Order:** 17111269

**Client Project:** Drinking Water Testing - Walsh

**Report Date:** 28-Nov-17

**Lab ID:** 17111269-007

**Client Sample ID:** A. WF by Rm 100

**Matrix:** DRINKING WATER

**Collection Date:** 11/18/2017 7:57

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	11/28/2017 11:47	136585



# Laboratory Results

<http://www.teklabinc.com/>

**Client:** Cook County School District 104  
**Client Project:** Drinking Water Testing - Walsh  
**Lab ID:** 17111269-008  
**Matrix:** DRINKING WATER

**Work Order:** 17111269  
**Report Date:** 28-Nov-17  
**Client Sample ID:** B. WF by Rm 100  
**Collection Date:** 11/18/2017 7:58

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	11/28/2017 11:52	136585



# Laboratory Results

<http://www.teklabinc.com/>

**Client:** Cook County School District 104  
**Client Project:** Drinking Water Testing - Walsh  
**Lab ID:** 17111269-009  
**Matrix:** DRINKING WATER

**Work Order:** 17111269  
**Report Date:** 28-Nov-17  
**Client Sample ID:** A. Kitchen  
**Collection Date:** 11/18/2017 7:59

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	11/28/2017 11:58	136585



# Laboratory Results

<http://www.teklabinc.com/>

**Client:** Cook County School District 104  
**Client Project:** Drinking Water Testing - Walsh  
**Lab ID:** 17111269-010  
**Matrix:** DRINKING WATER

**Work Order:** 17111269  
**Report Date:** 28-Nov-17  
**Client Sample ID:** B. Kitchen  
**Collection Date:** 11/18/2017 8:00

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	11/28/2017 12:03	136585



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Cook County School District 104

**Work Order:** 17111269

**Client Project:** Drinking Water Testing - Walsh

**Report Date:** 28-Nov-17

**Lab ID:** 17111269-011

**Client Sample ID:** A. WF Rm 106

**Matrix:** DRINKING WATER

**Collection Date:** 11/18/2017 7:50

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	11/28/2017 13:01	136585





# Laboratory Results

<http://www.teklabinc.com/>

**Client:** Cook County School District 104  
**Client Project:** Drinking Water Testing - Walsh  
**Lab ID:** 17111269-012  
**Matrix:** DRINKING WATER

**Work Order:** 17111269  
**Report Date:** 28-Nov-17  
**Client Sample ID:** B. WF Rm 106  
**Collection Date:** 11/18/2017 7:51

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	11/28/2017 13:06	136585



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Cook County School District 104

**Work Order:** 17111269

**Client Project:** Drinking Water Testing - Walsh

**Report Date:** 28-Nov-17

**Lab ID:** 17111269-013

**Client Sample ID:** A. WF Rm 101

**Matrix:** DRINKING WATER

**Collection Date:** 11/18/2017 7:54

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		2.1	µg/L	1	11/28/2017 13:12	136585



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Cook County School District 104

**Work Order:** 17111269

**Client Project:** Drinking Water Testing - Walsh

**Report Date:** 28-Nov-17

**Lab ID:** 17111269-014

**Client Sample ID:** B. WF Rm 101

**Matrix:** DRINKING WATER

**Collection Date:** 11/18/2017 7:55

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	11/28/2017 13:17	136585



## Laboratory Results

<http://www.teklabinc.com/>

Client: Cook County School District 104

Work Order: 17111269

Client Project: Drinking Water Testing - Walsh

Report Date: 28-Nov-17

Lab ID: 17111269-015

Client Sample ID: A. WF Rm 115

Matrix: DRINKING WATER

Collection Date: 11/18/2017 8:10

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	11/28/2017 14:15	136610



# Laboratory Results

<http://www.teklabinc.com/>

**Client:** Cook County School District 104

**Work Order:** 17111269

**Client Project:** Drinking Water Testing - Walsh

**Report Date:** 28-Nov-17

**Lab ID:** 17111269-016

**Client Sample ID:** B. WF Rm 115

**Matrix:** DRINKING WATER

**Collection Date:** 11/18/2017 8:11

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	11/28/2017 14:20	136610



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Cook County School District 104

**Work Order:** 17111269

**Client Project:** Drinking Water Testing - Walsh

**Report Date:** 28-Nov-17

**Lab ID:** 17111269-017

**Client Sample ID:** A. Sec. Floor Teachers Lounge

**Matrix:** DRINKING WATER

**Collection Date:** 11/18/2017 8:20

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		1.5	µg/L	1	11/28/2017 14:26	136610



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Cook County School District 104

**Work Order:** 17111269

**Client Project:** Drinking Water Testing - Walsh

**Report Date:** 28-Nov-17

**Lab ID:** 17111269-018

**Client Sample ID:** B. Sec. Floor Teachers Lounge

**Matrix:** DRINKING WATER

**Collection Date:** 11/18/2017 8:21

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	11/28/2017 14:31	136610



## Laboratory Results

<http://www.teklabinc.com/>

**Client:** Cook County School District 104

**Work Order:** 17111269

**Client Project:** Drinking Water Testing - Walsh

**Report Date:** 28-Nov-17

**Lab ID:** 17111269-019

**Client Sample ID:** A. Rm 201 WF

**Matrix:** DRINKING WATER

**Collection Date:** 11/18/2017 8:15

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	11/28/2017 13:23	136610





# Laboratory Results

<http://www.teklabinc.com/>

**Client:** Cook County School District 104  
**Client Project:** Drinking Water Testing - Walsh  
**Lab ID:** 17111269-020  
**Matrix:** DRINKING WATER

**Work Order:** 17111269  
**Report Date:** 28-Nov-17  
**Client Sample ID:** B. Rm 201 WF  
**Collection Date:** 11/18/2017 8:16

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	11/28/2017 14:37	136610



# Laboratory Results

<http://www.teklabinc.com/>

**Client:** Cook County School District 104  
**Client Project:** Drinking Water Testing - Walsh  
**Lab ID:** 17111269-021  
**Matrix:** DRINKING WATER

**Work Order:** 17111269  
**Report Date:** 28-Nov-17  
**Client Sample ID:** A. Gallos Office  
**Collection Date:** 11/18/2017 8:04

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	11/28/2017 14:42	136610



# Laboratory Results

<http://www.teklabinc.com/>

**Client:** Cook County School District 104  
**Client Project:** Drinking Water Testing - Walsh  
**Lab ID:** 17111269-022  
**Matrix:** DRINKING WATER

**Work Order:** 17111269  
**Report Date:** 28-Nov-17  
**Client Sample ID:** B. Gallos Office  
**Collection Date:** 11/18/2017 8:05

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	11/28/2017 14:48	136610



# Laboratory Results

<http://www.teklabinc.com/>

**Client:** Cook County School District 104  
**Client Project:** Drinking Water Testing - Walsh  
**Lab ID:** 17111269-023  
**Matrix:** DRINKING WATER

**Work Order:** 17111269  
**Report Date:** 28-Nov-17  
**Client Sample ID:** A. D.S Teachers Lounge  
**Collection Date:** 11/18/2017 8:01

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	11/28/2017 14:54	136610



# Laboratory Results

<http://www.teklabinc.com/>

**Client:** Cook County School District 104  
**Client Project:** Drinking Water Testing - Walsh  
**Lab ID:** 17111269-024  
**Matrix:** DRINKING WATER

**Work Order:** 17111269  
**Report Date:** 28-Nov-17  
**Client Sample ID:** B. D.S Teachers Lounge  
**Collection Date:** 11/18/2017 8:02

Analyses	Certification	RL	Qual	Result	Units	DF	Date Analyzed	Batch
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>								
Lead	NELAP	1.0		< 1.0	µg/L	1	11/28/2017 14:59	136610



# Receiving Check List

<http://www.teklabinc.com/>

Client: Cook County School District 104

Work Order: 17111269

Client Project: Drinking Water Testing - Walsh

Report Date: 28-Nov-17

Carrier: FedEx

Received By: KF

Completed by: *Kalyn Foecke*  
On: 21-Nov-17  
Kalyn Foecke

Reviewed by: *Elizabeth A. Hurley*  
On: 21-Nov-17  
Elizabeth A. Hurley

Pages to follow: Chain of custody  Extra pages included

- Shipping container/cooler in good condition? Yes  No  Not Present  Temp °C **NA**
- Type of thermal preservation? None  Ice  Blue Ice  Dry Ice
- Chain of custody present? Yes  No
- Chain of custody signed when relinquished and received? Yes  No
- Chain of custody agrees with sample labels? Yes  No
- Samples in proper container/bottle? Yes  No
- Sample containers intact? Yes  No
- Sufficient sample volume for indicated test? Yes  No
- All samples received within holding time? Yes  No
- Reported field parameters measured: Field  Lab  NA
- Container/Temp Blank temperature in compliance? Yes  No

*When thermal preservation is required, samples are compliant with a temperature between 0.1°C - 6.0°C, or when samples are received on ice the same day as collected.*

- Water – at least one vial per sample has zero headspace? Yes  No  No VOA vials
- Water - TOX containers have zero headspace? Yes  No  No TOX containers
- Water - pH acceptable upon receipt? Yes  No  NA
- NPDES/CWA TCN interferences checked/treated in the field? Yes  No  NA

**Any No responses must be detailed below or on the COC.**

Samples were received at the Downers Grove office. AR 11/20/17

Samples were received at the Collinsville lab on 11/21/17 at 09:43. KF/EAH 11/21/17

Samples were checked for turbidity then preserved with nitric acid upon arrival at the laboratory.

B. WF Rm 115 is labeled as collected at 08:10 rather than 08:11. Anna Willis was notified of this error via work order summary. KF/EAH 11/21/17







# CHAIN OF CUSTODY

pg. 3 of 3 Work order # 1711269

**TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005**

<b>Client:</b> <u>Cook County School District 104</u> <b>Address:</b> <u>6021 S 74th Ave</u> <b>City / State / Zip:</b> <u>Summit, IL 60501</u> <b>Contact:</b> <u>Anna Willis</u> <b>Phone:</b> <u>(708) 728-3113</u> <b>E-Mail:</b> <u>awillis@sd104.us</u> <b>Fax:</b> _____	<b>Samples on:</b> <input checked="" type="checkbox"/> ICE <input type="checkbox"/> BLUE ICE <input type="checkbox"/> NO ICE _____ °C <b>Preserved in:</b> <input checked="" type="checkbox"/> LAB <input type="checkbox"/> FIELD <b>FOR LAB USE ONLY</b> <b>Lab Notes</b>  <b>Client Comments:</b> Collected in 250mL containers. Date & Time of Last Use: _____
---	---

Are these samples known to be involved in litigation? If yes, a surcharge will apply  Yes  No  
 Are these samples known to be hazardous?  Yes  No  
 Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section.  Yes  No

Project Name/Number		Sample Collector's Name		MATRIX										INDICATE ANALYSIS REQUESTED												
Drinking Water Testing																										
Results Requested		Billing Instructions		# and Type of Containers																						
<input type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other _____ <input type="checkbox"/> 3 Day (50% Surcharge)				UNPRES	HNO3	NaOH	H2SO4	HCL	MeOH	NaHSO4	OTHER	Drinking Water	Soil	Sludge	Special Waste	Groundwater	Lead									
Lab Use Only	Sample Identification	Date/Time Sampled																								
1711269-021	A Gallos office	11-18-17 8:04										X					X									
-022	B Gallos office	11-18-17 8:05										X					X									
-023	A D.S teachers living	11-18-17 8:01										X					X									
-024	B D.S teachers living	11-18-17 8:02										X					X									
	<del>A</del>	<del>11-18-17</del>																								
	<del>B</del>	<del>11-18-17</del>																								
	<del>A</del>	<del>11-18-17</del>																								
	<del>B</del>	<del>11-18-17</del>																								
<b>Relinquished By</b>			<b>Date/Time</b>			<b>Received By</b>			<b>Date/Time</b>																	
						Kroedke Fed Gr			11/21/17 9:43																	

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See [www.teklabinc.com](http://www.teklabinc.com) for terms and conditions.

BottleOrder: 40295

